

RTI REQUEST DETAILS		
Registration No. :	CSLTD/R/E/24/00061	Date of Receipt : 06/12/2024
Type of Receipt :	Online Receipt	Language of Request : English
Name :		Gender :
Address :		
State :		Country :
Phone No. :		Mobile No. :
Email :		
Status(Rural/Urban) :		Education Status :
Is Requester Below Poverty Line ? :		Citizenship Status
Amount Paid :		Mode of Payment
Does it concern the life or Liberty of a Person ? :		Request Pertains to :
Information Sought :	As an HSE point, 1. I would like to know how many roof extractors in CSL shops are unserviceable ? 2. If yes , Since when are they unserviceable ? 3. What action the CSL has taken to repair them ?	
<div>PrintSaveClose</div>		



CSL/SEC/CS/CORRESP/RTI/2024/7

January 01, 2025

Sub: Information Under Right to Information Act

Dear Sir,

1. Please refer your RTI request no. CSLTD/R/E/24/00061 dated December 06, 2024. The reply to the information sought under the said request is given below:

- (i) How many roof extractors in CSL shops are unserviceable ?

Reply

As on date 21 Nos. Roof extractors out of 169 Nos. are faulty.

- (ii) If yes, Since when are they unserviceable ?

Reply

Within last two months.

- (iii) What action the CSL has taken to repair them ?

Reply

Action taken for rectification for some of the items. Some items will be replaced with turbine ventilators along with roof sheet replacement works. Regular maintenance is carried out to ensure proper ventilation in the shop which is an ongoing process.

2. If you are not satisfied with the above reply, you may prefer an appeal within 30 days from the date of receipt of this letter to Shri Bejoy Bhasker, Director (Technical) & Appellate Authority, Cochin Shipyard Limited, Administrative Building, Cochin Shipyard Premises, Perumanoor, Kochi – 682 015.

Thanking You,

Yours faithfully,

Digitally signed by
Syamkamal N
Date: 2025.01.01 11:59:25
+05'30'

Syamkamal N
Company Secretary & CPIO